



# Certificate / Certificat Zertifikat / 合格証

VEL 1405020 C006

*exida* hereby confirms that the:

## Pressure Seal Gate Valves

**Velan**

**Montreal, QC - Canada**

Has been assessed per the relevant requirements of:

**IEC 61508 : 2010 Parts 1-7**

and meets requirements providing a level of integrity to:

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A, Route 2<sub>H</sub> Device**

**PFD<sub>AVG</sub> and Architecture Constraints  
must be verified for each application**

### Safety Function:

The Valve will move to the designed safe position per the actuator design within the specified safety time.

### Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer  
may use the mark:



Revision 2.0 June 21, 2018  
Surveillance Audit Due  
June 1, 2021



ANSI Accredited Program  
ISO/IEC 17065  
PRODUCT CERTIFICATION BODY  
#1004



Evaluating Assessor

Certifying Assessor

VEL 1405020 C005

**Systematic Capability: SC 3 (SIL 3 Capable)**

**Random Capability: Type A, Route 2<sub>H</sub> Device**

**PFD<sub>avg</sub> and Architecture Constraints  
must be verified for each application**

**Systematic Capability :**

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

**Random Capability:**

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2<sub>H</sub>.

**IEC 61508 Failure Rates in FIT\*, Pressure Seal Flexible Wedge Gate Valve, Clean Service**

Device	$\lambda_{SD}$	$\lambda_{SU}$	$\lambda_{DD}$	$\lambda_{DU}$
Full Stroke	0	0	0	449
Tight-Shutoff	0	0	0	920
Open on Trip	0	103	0	346
Full Stroke with PVST	0	0	187	261
Tight-Shutoff with PVST	0	0	187	732
Open on Trip with PVST	103	0	187	159

\* FIT = 1 failure / 10<sup>9</sup> hours

† PVST = Partial Valve Stroke Test of a final element Device

**SIL Verification:**

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD<sub>avg</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

**Assessment Report:** VEL 14-05-020 Velan Assessment Report R003 V2R1  
Safety Valves IEC 61508 Assessment (or later)

**Safety Manual:** SIL-MTV-10-14



80 N Main St  
Sellersville, PA 18960